



STEDRANT TECHNOCLINIC PVT. LTD.
(Construction Materials Testing Laboratory)

Lab: # 39/5, Govardhan Garden, J C Industrial Area, Yelechenahalli, off. Kanakapura Main Road,
Bangalore - 560062. Ph.: 080 26860348. E-mail : labblr@stedrant.com CIN: U74999KA2017PTC100477
GST No.: 29AAYCS1231L1ZQ www.stedrant.com

DOC: STPL/RF/05/SPL

Ref: STPL/SPL/BLR/525/4/2023/3/S

Job Order dated: 29.04.2023

Page 1 of 1

Date: 03.05.2023

M/s. Pronil Building Products
XII, Aringar, Anna road,
Co-operative Nagar, Thiruvankadu
Chennai - 600077



CHEMICAL TEST REPORT ON PROFLEX 3 PLY SAMPLE

Source of sample : Sample supplied by the customer
Date of receipt of the test sample : 20.04.2023
Customer's Reference : Letter dated 05.04.2023
UIN : 237400
Project : Not Furnished
Brand # : Pronil PROFLEX 3 PLY
Period of test : 02.05.2023 to 03.05.2023
Condition of sample : Satisfactory
Test Method : Laboratory developed method

Sl. No.	Description of the Test	Observation
1	For testing the chemical resistance, the test samples were immersed in the following test solutions, allowed to stand for 24 hours and washed with water and inspected for visual observation. The test solutions used as mentioned below: a. Hydrochloric acid (3% solution) b. Sodium hydroxide (3% solution) c. Sodium chloride (3% solution) d. Citric acid (3% solution) e. Acetic acid (3% solution) f. Sulphuric (3% solution) g. Ammonium Chloride (3% solution) h. Potassium hydroxide (3% solution)	The tested sample do not shows blistering, staining or discoloration after the completion of the test.

As furnished by the customer.

- Note:**
1. The results relate only to the samples tested.
 2. Report shall not be reproduced, except in full, without the written approval of the lab.
 3. Any correction invalidates this report.

for **STEDRANT TECHNOCLINIC PVT LTD.**


31/5/23
 Mr. Radhakrishna
STPL Manager-Lab

End of the report

(Soil and Material Testing, Designs, Restoration and Non Destructive Testing Services)

Corporate Office :

"Sunvak Pride" # 95, Model House Street, Basavanagudi,
Bangalore - 560 004. Ph : 080 26629992

Hyderabad Off./ Lab :

Shed No. F-3/A, Street No. 10, IDA, Nacharam, Hyderabad - 500076.
Mob : +91 9000085790, +91 9000095790, +91 9908875790, +91 9908065790